

TECHNICAL SPECIFICATION Hall B

Bielany Wrocławskie ul. Logistyczna 4

Certification: none



Area

<i>Terrein</i>	Entrance, gate / concierge, fence, maneuvering area for trucks, parking for passenger cars - 337 places
<i>Building</i>	One-storey warehouse with a reserve for two-storey office and social space. Clear height in the storage area 10 m (to the main beams).
<i>Exterior facade</i>	<ul style="list-style-type: none">• Walls of prefabricated concrete elements with a height of:<ul style="list-style-type: none">> from -1.10 to 4.20 m at the docks> from 0.00 to 4.20 m at the "entrance" from level 0> from 0.00 to 0.30 m in other parts of the building, except for office premises• Sandwich panels in horizontal orientation with PIR filling, 10 cm thick• Basic color of external walls and window joinery - light gray RAL 9006, color of dock gates, technical doors and attic strip - blue RAL 5003



Warehouse part

<i>Fire load</i>	Fire load up to 4000 MJ / m ² , axes: (11-21; E-L) over 4000 MJ / m ²
<i>Column grid</i>	Column grid with a spacing of 22.5 m x 12 m and 22.5 x 24 m at the unloading docks.
<i>The floor plate</i>	<ul style="list-style-type: none">• Uniformly distributed load of 50kN / m².• The floor slab - reinforced concrete, 17 cm thick (reinforced: dispersed reinforcement).• Surface hardening: dry mineral sprinkle, dust-free floor.• Surface flatness according to DIN 18202, table 3, line 3• Thermal insulation of ground beams, internal circumference.• Prefabricated reinforced concrete perimeter beams.• Jointless concrete floor (with a maximum area of 2500 m²).• Prefabricated reinforced concrete dock sockets.
<i>Supporting structure</i>	<ul style="list-style-type: none">• Reinforced concrete columns, main steel beams.• 22.5 m x 12 m and 22.5 m x 24 m column grid at unloading docks. Steel structure protected against corrosion.• In the front part of the docks, a reinforced concrete wall as a substructure for sectional gates.

<i>Sectional doors</i>	<ul style="list-style-type: none"> • Overhead sectional doors with electric drive: • 3 m x 3.2 m sectional docks with glazed section (amount: 68) • 3.5 m x 4.2 m entrance gates from level 0 (amount: 10).
<i>Transshipment platforms</i>	<ul style="list-style-type: none"> • Electric Hörmann type; nominal load capacity 60 kN • Lip length 0.405 m, platform width 2.0 m. • Platform length 2.50 m, height 0.6 m, steel structure. • Dock height: 1.20 m • Dock seal: apron. Two rubber buffers with dimensions of 500x250x100mm at each loading platform. Trailer wheel guides for each loading platform - made of cubes.
<i>Roof</i>	The warehouse roof is flat, sheathing made of trapezoidal sheet metal, 0.63 mm thick, powder coated in a standard color. Roof insulation - hard mineral wool covered with a PVC membrane with a thickness of 1.2 mm. Design internal temperature in the storage area +15 ° C, at an outside temperature of -20 ° C.
<i>Roof drainage</i>	Underpressure roof drainage installation, emergency overflows in the walls of the attic.
<i>Lighting the warehouse area</i>	Access to daylight in the storage area - through smoke vents and skylights (lighting area in total 2% of the floor plan). Transparent polycarbonate filling. Starting the smoke exhaust from the sprinkler pump station.
<i>Door accessories</i>	Anti-panic mechanisms in all emergency exits. Door closers in fire-resistant doors and in the entrance door of the main office area.



Office part

<i>Fire resistance category and class</i>	ZL III
<i>Offices and communication</i>	<ul style="list-style-type: none"> • Height of offices - 3m in the light. • Internal plasterboard walls, 100 mm thick, on steel system profiles with acoustic insulation made of mineral wool, painted with emulsion paint. • Finishing of the floors: carpet (Modulyss) in offices, ceramic tiles in social areas. • Ceiling finishing: mineral system suspended ceiling on a grid, panels 60 cm x 60 cm in white. • Aluminum window frames, powder coated in RAL 5003 color • Internal paneled doors (Porta), steel frame, powder coated in a standard color.
<i>Technical rooms</i>	<ul style="list-style-type: none"> • Floor finish: faded concrete. • Finishing of walls: double painting with emulsion paint. • Doors: metal technical.

<i>Sanitary facilities</i>	<ul style="list-style-type: none"> • Internal plasterboard walls, 100 mm thick, double-paneled (waterproof board) on steel system profiles with acoustic insulation made of mineral wool, painted with emulsion paint. • Floor finishing: 30 cm x 30 cm ceramic tiles in a standard color. • Wall finishing: tiles up to 2m high, showers up to full height. • Ceiling finishing: mineral system ceiling suspended on a grid, panels 60 cm x 60 cm in white, waterproof. • Sanitary equipment: white ceramic sanitary ware (Circle). • Sanitary equipment: hangers, towel dispensers, soap dispensers (Merida).
----------------------------	---



Sanitary and mechanical installations

<i>Sanitary installations</i>	<p>Sanitary sewage system: combined</p> <p>Storm sewer: water discharge based on a water-legal permit.</p> <p>Industrial sewage system: none.</p> <p>Water supply system for social and living purposes - powering the municipal network.</p>
<i>Fire protection</i>	<p>ESFR sprinkler system (K240 heads) in the storage part, water supply for fire purposes from the fire tank. Internal hydrants and handheld firefighting equipment on the storage area in accordance with local regulations and requirements. External hydrants located on the premises of the facility. Permissible fire load on the warehouse part: up to 4,000 MJ / m² and in the axes: (11-21; E-L) above 4,000 MJ / m².</p>
<i>Heating and ventilation</i>	<p>Heating in the storage area - gas heaters. Design internal temperature in the warehouse section: + 18 ° C in the warehouse along the L-T2 / 1-21 axis and + 15 ° C for other storage spaces, at an external temperature of - 20 ° C. In the office part, central heating is supplied from a gas boiler room. Calculated internal temperature in the office part: 20 degrees C, outside temperature - 20 ° C. Heating in sanitary facilities locally - electric heaters.</p> <p>Ventilation in the storage area:</p> <p>Exhaust: mechanical 0.25 dim / h, Tywent roof exhaust fans.</p> <p>Air supply: through entrance gates.</p> <p>Ventilation system: based on smoke vents</p> <p>Ventilation in the office and social part:</p> <p>In accordance with applicable regulations and tenant's standards</p>



Electrical Installations

<i>General</i>	<ul style="list-style-type: none"> • 800 kVA power supply for a hall with a storage area of 30,000 m2. • Energy distribution: main switchgear, object switchgears. • Power supply: 230/400 V. • Electricity consumption billed by sub-meters. One meter per module of warehouse space. Main meter at the SN WRW-4107 station, indirect metering, serving three halls: A, A2, B. • Power supply for the workplace: two sockets on an 8m2 purely office space. • Cleaning and general purpose sockets: one cleaning socket for every 20 m2 of room (corridors, sanitary facilities, lockers, cleaning room, technical room). • General purpose sockets in kitchenettes: 4 pcs. • In the warehouse part - a set of single-phase general-purpose sockets located at the loading platform, 2 pcs +1 force socket (1 set per 3000 m2 of the hall) • Lightning protection - horizontal and vertical lightning rods.
<i>Lighting</i>	<ul style="list-style-type: none"> • Outdoor lighting - LED • Internal lighting fluorescent lamps: • 200 lux in the warehouse (before check-in), in sanitary rooms, corridors and staircases) • 150 lux in technical rooms • 500 lux in offices • Emergency lighting / signage for emergency exits at all emergency exits
<i>Telecommunication</i>	<p>Teletechnical connections: Netia or other (individually for each tenant)</p>